

BRE Global Limited

Bucknalls Lane, Garston, Watford, Hertfordshire, United Kingdom WD25 9XX

Telephone: +44(0)1923 664100 Fax: +44(0)1923 664603 E-mail: enquiries@breglobal.co.uk Web: www.breglobal.co.uk

EC-CERTIFICATE OF CONFORMITY

0832 - CPD - 0330

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

NFXI-BEAM Analogue addressable beam detector with short circuit isolator for use in fire detection and alarm systems

(For conditions of use for the product see the attached appendix)

placed on the market by

Notifier By Honeywell

Charles Avenue, Burgess Hill, West Sussex, RH15 9UF

and produced in the factory

Pittway Tecnologica Srl.

Via Caboto 19/3, 34147 TRIESTE, Italy


is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan. The initial type-testing for the relevant characteristics of the product, the initial inspection and continuous surveillance of the factory and factory production control has been performed under the control of the approved body BRE Global Limited.

This certificate attests that all provisions concerning the attestation of conformity (Level 1) and the performances described in Annex ZA of the standard(s)

EN 54 - 12: 2002 - Smoke detectors - Line detectors using an optical light beam EN 54 - 17: 2005 - Short circuit isolators

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 21/12/2005 and remains valid as long as the product continues to be manufactured and the conditions laid down in the harmonised technical specification referenced or the manufacturing conditions in the factory or the FPC itself are not modified significantly and the required annual FPC assessments are maintained.



Martin McCullagh
Certification Manager
For and on behalf of BRE Global Limited

Date Of Issue: 5/4/2012
Issue Number: 4
Page: 1 of 2

This certificate remains the property of BRE Global Limited and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.
To check the authenticity of this certificate, please visit our website or contact us.

BRE Global Limited

Bucknalls Lane, Garston, Watford, Hertfordshire, United Kingdom WD25 9XX

Telephone: +44(0)1923 664100 Fax: +44(0)1923 664603 E-mail: enquiries@breglobal.co.uk Web: www.breglobal.co.uk

Appendix to EC Certificate of conformity 0832 - CPD - 0330

The details and conditions of use for the NFXI-BEAM Analogue addressable beam detector with short circuit isolator, placed on the market by Notifier By Honeywell, Charles Avenue, Burgess Hill, West Sussex, RH15 9UF are:

To be used in accordance with the suppliers installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Ancillaries:

RTS151-KEY Remote Test Station

6500-LRK/BEAMLRK Long Range Kit

6500-MMK/BEAMMMK Multi-Mounting Kit


6500-SMK/BEAMSMK Surface Mounting Kit

Sensitivities:

Sensitivity settings 1, 2, 3, 4 & acclimate levels 1 & 2

Variants:

NFXI-BEAM-T - With self test facility



Martin McCullagh
Certification Manager
For and on behalf of BRE Global Limited

Date Of Issue: 5/4/2012

Issue Number: 4

Page: 2 of 2

This certificate remains the property of BRE Global Limited and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.

To check the authenticity of this certificate, please visit our website or contact us.